



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS1A 106093 0003 Rev. 00

Initial No. -

Certificate Holder:

Lingjack Engineering Works Pte Ltd  
No. 1 Woodlands Terrace  
Singapore 738471  
SINGAPORE

UEN - 199103053M

Certification Mark:



Product:

Fire Extinguishers

Brand Name:

COMBAT

Model(s):

C-2HBSE, C-4HBSE

Product Details:

2kg, 4kg  
Halotron® BrX Stored Pressure Type Portable Fire Extinguisher

Standard(s):

SS EN 3-7:2012  
SS EN 3-8:2012

Country of Origin:

Singapore

Test Report(s):

7191313903-MEC23/01A-FA, 7191313903-MEC23/02A-FA, PSB  
Assess 7191313903-MEC23/01B-DA, PSB Assess 7191313903-  
MEC23/02B-DA

Valid until:

2028-08-25

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

Issued on: 2023-09-22

Vice-President (Certification Department)  
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert). For more information on TÜV SÜD PSB Pte Ltd product certification: [www.tuvsud.com/sg](http://www.tuvsud.com/sg)

# CERTIFICATE OF CONFORMITY

No. CLS1A 106093 0003 Rev. 00

Initial No. -

## Product Details:

Table 1 Fire Ratings and specifications of 2kg, 4kg Halotron® BrX Stored Pressure Type Portable Fire Extinguisher

No.	Model	Type	Fire Rating Achieved
1	C-2HBSE	2kg Halotron® BrX Stored Pressure Type Portable Fire Extinguisher	5A / 34B
2	C-4HBSE	4kg Halotron® BrX Stored Pressure Type Portable Fire Extinguisher	13A / 70B

Page 2 of 2

Issued on: 2023-09-22



Vice-President (Certification Department)  
TÜV SÜD PSB



SAC Accredited  
Certification  
Body  
PD-2002-01

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert). For more information on TÜV SÜD PSB Pte Ltd product certification: [www.tuvsud.com/sg](http://www.tuvsud.com/sg)