

CERTIFICATE OF CONFORMITY

This Certificate is issued to

LINGJACK ENGINEERING WORKS PTE LTD

(UEN No.: 199103053M)

No.1 Woodlands Terrace #03-01 Lingjack Industrial Building Singapore 738471

For Product Certification Scheme: Type 5

Product : **Portable Fire Extinguisher**

Brand : **COMBAT**

Model : **C-1ASE, C-2ASE, C-3ASE, C-4ASE, C-6ASE, C-9ASE, C-9PKSE, C-9MSE**

Country of Origin : **Singapore**

Product Details : **Stored pressure dry powder type fire extinguisher.
Refer to Appendix for fire rating.**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS EN 3-7: 2012
EN 3-8: 2006

TEST REPORT(S)

SETSCO Test Report No.: MM-8500071362/CCH
BRE Test Report No.: 252194
BRE Test Report No.: 252195
BRE Test Report No.: 237709
BRE Test Report No.: 252197
BRE Test Report No.: 252196
SETSCO Test Report No.: MM-50071/CCH/4
SETSCO Assessment Report No.: MM-8500170175/CY SETSCO
Test Report No.: MM-850092207/CCH

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23
Singapore 659547

Certificate No
FSP-2013-0128

Date of Issue
30/01/2023

Date of Expiry
22/03/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10

Model	Type	Fire Rating	Capacity
C-1ASE	ABC Powder, Stored Pressure	5A/55B	1kg
C-2ASE	ABC Powder, Stored Pressure	13A/55B	2kg
C-3ASE	ABC Powder, Stored Pressure	13A/55B	3kg
C-4ASE	ABC Powder, Stored Pressure	21A/144B	4kg
C-6ASE	ABC Powder, Stored Pressure	34A/233B	6kg
C-9ASE	ABC Powder, Stored Pressure	43A/233B	9kg
C-9PKSE	Purple K BC powder, stored pressure	233B	9kg
C-9MSE	Monnex BC Powder, stored pressure	233B	9kg



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No
FSP-2013-0128

Date of Issue
30/01/2023

Date of Expiry
22/03/2028

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.