

CERTIFICATE OF CONFORMITY

This Certificate is issued to

LINGJACK ENGINEERING WORKS PTE LTD

(UEN No.: 199103053M)

No.1 Woodlands Terrace #03-01 Lingjack Industrial Building Singapore 738471

For Product Certification Scheme: Type 5

Product : **Portable Fire Extinguisher**

Brand : **COMBAT**

Model : **C-2CSEC, C-5CSEC**

Country of Origin : **Singapore**

Product Details : **Stored pressure carbon dioxide type fire extinguisher**

Model	Capacity	Fire Rating	Test Report
C-2CSEC	2kg	34B	242435
C-5CSEC	5kg	55B	242436

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS EN 3-7: 2012
EN 3-9: 2006

TEST REPORT(S)

SETSCO Test Report No.: MM-8500092207/CCH
BRE Test Report No.: 242435
BRE Test Report No.: 242436

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23
Singapore 659547

Certificate No
FSP-2020-0982

Date of Issue
30/01/2023

Date of Expiry
22/03/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10