



## CERTIFICATE OF CONFORMITY

This Certificate is issued to

LINGJACK ENGINEERING WORKS PTE LTD

(UEN No.: 199103053M)

No.1 Woodlands Terrace #03-01 Lingjack Industrial Building Singapore 738471

For Product Certification Scheme: Type 5

**Product** 

Portable Fire Extinguisher

**Brand** 

: COMBAT

Model

: C-9FSE, C-9WSEA, EX-WM1, EX-WM2, EX-WM3, EX-WM6,

EX-WM9, EX-GFM2, EX-GFM6, C-2AWM, C-6AWM

**Country of Origin** 

: Singapore

**Product Details** 

Stored pressure water based type fire extinguisher.

Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

**TEST REPORT(S)** 

SS EN 3-7: 2012

SETSCO Test Report No.: MM-8500092207/CCH

EN 3-8: 2006

Refer to Appendix

Detailed configuration and installation shall be referenced to the certified report(s) stated above.

**Dixon Ng (Mr)**Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No

Date of Issue

Date of Expiry

FSP-2020-1029

30/01/2023

22/03/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.





Model	Capacity	Fire Rating	Test Report No.
C-9FSE	9L	34A, 233B	BRE 252297
C-9WSEA	9L (water additive)	21A	BRE 254220
EX-WM1	1.4L	5A	MPA Dresden 20141670/TE01 Apragaz 155729
EX-WM2	2L	5A, 25F	MPA Dresden 20141656/TE02 Apragaz U167183
EX-WM3	3L	8A, 25F	MPA Dresden 20141656/TE03 Apragaz 155729
EX-WM6	6L	13A, 40F	MPA Dresden 20141656/TE04 Apragaz 155729
EX-WM9	9L	21A, 40F	MPA Dresden 20141656/TE05 Apragaz 155729
C-2AWM	2: (water mist with additive)	8A, 25F	MPA Dresden 20171326/LG01 Apragaz U167183
C-6AWM	6L (water mist with additive)	21A, 40F	MPA Dresden 20171326/LG02 Apragaz 155729
EX-GFM2	2L (water mist with additive)	5A, 55B, 25F	MPA Dresden 20141656/TE06 Apragaz U167183
EX-GFM6	6L (water mist with additive)	13A, 144B, 40F	MPA Dresden 20141656/TE07 Apragaz 155729

Dixon Ng (Mr) Program Manager SETSCO Services Pte Ltd 531 Bukit Batok Street 23, Singapore 659547

Certificate No FSP-2020-1029 Date of Issue 30/01/2023

Date of Expiry 22/03/2028