

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

**LINGJACK ENGINEERING WORKS PTE LTD**

**(UEN No.: 199103053M)**

**No. 1 Woodlands Terrace, #03-01 Industrial Building, Singapore 738471**

**For Product Certification Scheme: Type 5**

**Product : Mobile Fire Extinguisher**

**Brand : COMBAT**

**Model : Refer to Appendix**

**Country of Origin : Singapore**

**Product Details : Refer to Appendix**

which has complied with the requirements of the scheme based on the following:

**STANDARD(S) TEST REPORT(S)**

BS EN 1866-1: 2007

Refer to Appendix

**Detailed configuration and installation shall be referenced to the certified report(s) stated above.**



**Fiona Leong (Ms)**  
Program Manager  
SETSCO Services Pte Ltd

**Certificate No**  
**BCM-2019-0060**

**Date of Issue**  
**03/07/2024**

**Date of Expiry**  
**27/07/2027**

*\*This product is not under the SCDF list of regulated fire safety products/materials.*

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

| Model    | Capacity & Type of Mobile Fire Extinguisher                             | Fire Rating      | Test Report No. |
|----------|---|------------------|-----------------|
| C-25ATP  | 25kg ABC Powder, Stored Pressure  | 34A, II B (275B) | 277267          |
| C-50ATP  | 50kg ABC Powder, Stored Pressure  | 34A, II B (275B) | 277268          |
| C-50ATC  | 50kg ABC Powder, 1.5 KG CO <sub>2</sub> Cartridge Operated              | 34A, IV B (317B) | 277270          |
| C-75ATC  | 75kg ABC Powder, 3 KG CO <sub>2</sub> Cartridge Operated                | 34A, IV B (317B) | 277271          |
| C-100ATC | 100kg ABC Powder, 3.5 KG CO <sub>2</sub> Cartridge Operated             | 34A, IV B (317B) | 277272          |
| C-150ATC | 150kg ABC Powder, 4 KG CO <sub>2</sub> Cartridge Operated               | 34A, IV B (317B) | 277273          |
| C-25PTP  | 25kg BC Purple K Powder, Stored Pressure                                | II B (275B)      | 277279          |
| C-50PTP  | 50kg BC Purple K Powder, Stored Pressure                                | II B (275B)      | 277280          |
| C-50PTC  | 50kg Purple K BC Powder, 1.5 KG CO <sub>2</sub> Gas Cartridge Operated  | IV B (317B)      | 277281          |
| C-75PTC  | 75kg Purple K BC Powder, 3 KG CO <sub>2</sub> Gas Cartridge Operated    | IV B (317B)      | 277282          |
| C-100PTC | 100kg Purple K BC Powder, 3.5 KG CO <sub>2</sub> Gas Cartridge Operated | IV B (317B)      | 277283          |
| C-150PTC | 150kg Purple K BC Powder, 4 KG CO <sub>2</sub> Gas Cartridge Operated   | IV B (317B)      | 277284          |
| C-25MTC  | 25kg Monnex BC Powder, 1 KG CO <sub>2</sub> Gas Cartridge Operated      | III B (296B)     | 277275          |
| C-50MTC  | 50kg Monnex BC Powder, 1.5kg CO <sub>2</sub> Gas Cartridge Operated     | III B (296B)     | 277276          |
| C-100MTC | 100kg Monnex BC Powder, 3.5 KG CO <sub>2</sub> Cartridge Operated       | III B (296B)     | 277278          |
| C-25FTP  | 25 Litre Foam, Stored Pressure  | 34A, II B (275B) | 277285          |
| C-50FTP  | 50 Litre Foam, Stored Pressure  | 34A, II B (275B) | 277286          |
| C-50FTC  | 50 Liter Foam, 1 KG CO <sub>2</sub> Gas Cartridge Operated              | 34A, IV B (317B) | 277287          |
| C-100FTC | 100 Litre Foam, 2 KG CO <sub>2</sub> Gas Cartridge Operated             | 34A, IV B (317B) | 277288          |
| C-135FTC | 135 Litre Foam, 3 KG CO <sub>2</sub> Gas Cartridge Operated             | 34A, IV B (317B) | 277289          |
| C-20C    | 20kg CO <sub>2</sub> Stored Pressure                                    | 89B              | 280614          |
| C-30C    | 30kg CO <sub>2</sub> Stored Pressure                                    | 113B             | 280615          |



**Fiona Leong (Ms)**  
Program Manager  
SETSCO Services Pte Ltd

**Certificate No**  
**BCM-2019-0060**

**Date of Issue**  
**03/07/2024**

**Date of Expiry**  
**27/07/2027**

*\*This product is not under the SCDF list of regulated fire safety products/materials.*

*Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.*