

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

**LINGJACK ENGINEERING WORKS PTE LTD**

**(UEN No.: 199103053M)**

**No.1 Woodlands Terrace #03-01 Lingjack Industrial Building Singapore 738471**

**For Product Certification Scheme: Type 5**

**Product : Standby Fire Hose**

**Brand : COMBAT**

**Model : T3**

**Country of Origin : Singapore**

**Product Details : 64mm diameter layflat hose**

which has complied with the requirements of the scheme based on the following:

**STANDARD(S)**

BS 6391: 2009

**TEST REPORT(S)**

BSI Test Report No.: 8869043-2

**Detailed configuration and installation shall be referenced to the certified report(s) stated above.**

SETSCO



**Fiona Leong (Ms)**  
Program Manager  
SETSCO Services Pte Ltd

**Certificate No**

**FSP-2010-0005**

**Date of Issue**

**04/12/2024**

**Date of Expiry**

**28/12/2029**

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10