

## TEST REPORT

(This Report is issued subject to the terms & conditions set out below)

**SetSCO Services Pte Ltd**  
531 Bukit Batok Street 23  
Singapore 659547  
Tel : (65) 6566 7777  
Fax: (65) 6566 7718  
www.setsco.com  
Business Reg. No. 196900269D

Date: 05<sup>th</sup> July 2024

Your Ref: -

Our Ref: MM-8500320387/MA

Page 1 of 3

**Subject** : Witnessing of Dimensional Measurement, Pressure & Flow Characteristics Test on Non-Controllable Two Way Pillar Hydrant submitted by Lingjack Engineering Works Pte Ltd on 04<sup>th</sup> July 2024.

**Tested for** : **LINGJACK ENGINEERING WORKS PTE LTD**  
No.1 Woodlands Terrace #03-01  
Lingjack industrial building  
Singapore 738471  
**Attn:** Mr. Liaw Zhu Yik

**Date & Place of Test** : 04<sup>th</sup> July 2024 at Lingjack Engineering Works Pte Ltd  
(1, Woodlands Terrace, Lingjack Industrial Building, Singapore 738471)

**Method of Test** : Based on BS EN 14384: 2005  
1) Dimensions (Client's Requirement & BS EN 1092-2 : 1997)  
2) Flow Characteristics  
3) Leaktightness  
4) Mechanical Strength

**Description of Sample** : One (01) unit of Non-Controllable Two Way Pillar Hydrant was tested as follows:

S/No.	Sample Reference	Brand	Model No.	Size	Emboss Marking	Qty
1	Non-Controllable Two Way Pillar Hydrant	COMBAT	PH-100	DN 100 (inlet) DN 65 (outlet)	COMBAT BS-750 DIA 100	01

**Results** : 1) Dimensions  
Refer to Table 1  
2) Flow Characteristics Test  
Refer to Table 2  
3) Leaktightness Test  
Refer to Table 3  
4) Mechanical Strength Test  
Refer to Table 4



**MOHAMMAD AZAM**  
Testing Officer



**CHEN YU**  
Manager (Mechanical Testing)  
Mechanical Technology Division

Note: For any statement of conformity stated in this test report, SETSCO shall adopt the Simple Acceptance as the decision rule in evaluating conformance to specification or standard.

### Terms & Conditions:

- (1) The Report is prepared for the sole use of the Client and is prepared based upon the Item submitted, the services required by the Client and the conditions under which the Services are performed by SETSCO. The Report is not intended to be representative of similar or equivalent Services on similar or equivalent items. The Report does not constitute an endorsement by SETSCO of the item.
- (2) SETSCO agrees to use reasonable diligence in the performance of the Services but no warranties are given and done may be implied directly or indirectly relating to the Services, the Report or the facilities of SETSCO.
- (3) The Report may not be used in any publicity material without the written consent of SETSCO.
- (4) The Report may not be reproduced in part or in full unless approval in writing has been given by SETSCO.
- (5) SETSCO shall under no circumstances be liable to the Client or its agents, servants or representatives, in contract, tort (including negligence or breach of statutory duty) or otherwise for any direct or indirect loss or damage suffered by the Client, its agents, servants or representative howsoever arising or whether connected with the Services provided by SETSCO herein.

**Results:****Table 1a: General Dimension Measurement**

Test Method	Sample Ref: Non-Controllable Two Way Pillar Hydrant Size: DN100	Client's Requirements
A (mm)	465	Min. 445.0 Max. 485.0
B (mm)	608	Min. 600.0 Max. 620.0
C (mm)	101.6	Nom. 100.0

Note: Refer to Appendix A

**Table 1b: Flange Dimension Measurement**

Test Method		Sample Ref: Non-Controllable Two Way Pillar Hydrant Size: DN100	BS EN 1092-2: 1997 Requirements
D (mm)		219.9	Nom. 220
K (mm)		179.9	Nom. 180
L (mm)		18.5	Min. 19 Max. 20.5
Bolts	Number	8	Nom. 8 Nos
	Size	M16	Nom. M16
Flange Thickness (mm)	C	20.9	Min. 16 Max. 23

Note: Refer to Appendix B

**Table 2: Flow characteristics (on 1 Outlet)**

Sample Reference	P <sub>1</sub> , Inlet Pressure (bar)	P <sub>2</sub> , Outlet Pressure (bar)	Q, Flow rate (l/m)
Non-Controllable Two Way Pillar Hydrant	1.8	0.9	1080

**Note:**

- 1) Inlet Pressure Gauge (Brand: BD SENSORS, 0~200 bar) Certificate number: BLP2305013-2S.
- 2) Outlet Pressure Gauge (Brand: CAPRI, 0~4 bar) Certificate number: SN-272530/70/01.
- 3) Flow Gauge (Brand: TSI, Model: EMF-300E, Serial Number 1922) Certificate number: ASN-23-4764 (Non-Singlas Report) .

**Table 3: Leaktightness Test (Shell Test)**

Sample Reference	Test Duration (min)	Test Pressure (bar)	Results	BS EN 14384: 2005 Requirements
Non-Controllable Two Way Pillar Hydrant	10	25	No leakage	Shall be no sign of leakage past the valve




**Results:****Table 4: Mechanical Strength Test**

Sample Reference	Results	BS EN 14384: 2005 Requirements
Non-Controllable Two Way Pillar Hydrant	No defects observed	Shall show no sign of defects

**Note:**


1) Pressure Gauge (Brand: BD SENSORS, 0~200 bar) Certificate number: BLP2305013-2S.

**Appendix A:**

Photograph 1 shows  
Pillar Fire Hydrant tested



Photograph 2 shows Pillar Hydrant under  
Flow Characteristic Test

**Appendix B:**




**BESTLABS SINGAPORE**  
PTE LTD.

19 Senoko Loop, #03-00/#03-01  
Singapore 758169  
☎ +65 6914 7777  
✉ +65 6914 7788  
✉ sales@calibration.sg  
Company Reg no. 201728718W  
GST no. 201728718W



**CERTIFICATE NO.** : BLP2305013-2S

**PAGE** 1 OF 2

**SUBMITTED TO** :

Lingjack Engineering Works Pte Ltd  
No.1 Woodlands Terrace  
#03-01  
Singapore 738471

**REFERENCE NO.** : BSO-23-005013

**RECEIVED DATE** : 17-Jul-2023

**ISSUED DATE** : 17-Jul-2023



Bestlabs organization and practices have been duly accredited and are compliant to the requirements of ISO/IEC 17025; the laboratory accreditation standard. Our Quality Management System ensures its compatibility with the requirements of ISO 9001:2015. The reference measurement standards used are traceable to the International System of Units (SI) through National Metrology Centre, (NMC, SINGAPORE) and/or other National Standards. The results reported herein have been performed in accordance with the terms of accreditation under the Singapore Accreditation Council.

TRUMENT		DIGITAL PRESSURE GAUGE			
MANUFACTURER	: BD SENSORS	AMB. TEMPERATURE	: (20 ± 1) °C		
MODEL NO.	: BAROLI 05	RELATIVE HUMIDITY	: (55 ± 10) % relative humidity		
SERIAL NO.	: 10865174 ✓	CALIBRATED DATE	: 17-Jul-2023 ✓		
RANGE	: {0~200} bar	DUE DATE	: 16-Jul-2024 ✓		
TAG NO.	: LIG-032 ✓	-	:-		
PART NO.	: -	-	:-		
LOCATION	: -	-	:-		
CALIBRATION AT	: BLS Laboratory	-	:-		
MEASUREMENT TRACEABILITY					
REFERENCE STANDARDS	CERTIFICATE NO.	SERIAL NO.	TAG NO.	CAL. DATE	DUE DATE
PRESSURE CALIBRATOR	23-C117634	211H11080009	BS 1511	27-Feb-2023	26-Feb-2024
METHOD OF CALIBRATION: BSM 01,ISSUE 04,REV 1 DATED JUL 2020.					

**NOTES:**

- The results of the calibration are given on the attached following pages.
- The expanded uncertainty of measurement associated with the calibration is estimated at a confidence level of approximately 95%.
- No adjustment was done unless otherwise stated.
- The user should determine the suitability of the instrument for its intended use.
- The reports shall not be reproduced except in full, without written approval by management representative of BESTLABS SINGAPORE PTE LTD.

**R RAMESH | TECHNICAL MANAGER**  
CALIBRATION OFFICER

**B REDHY | CTO**  
APPROVING OFFICER



**Calibration Report No. : SN - 272530 / 70 / 01**

(This Report is issued subject to the terms & conditions set out below)

**SetSCO Services Pte Ltd**  
531 Bukit Batok Street 23  
Singapore 659547  
Tel : (65) 6566 7777  
Fax: (65) 6566 7718  
www.setsco.com  
Business Reg. No. 196900269D

Your Ref : SN - 218970 / 218726 Our Ref : SN - 8500272530 / GSK / 70 / 01

Date : 30/07/2023

Page : 1 of 1

**CALIBRATION REPORT  
ON  
PRESSURE GAUGE**

**Issued To** : SETSCO SERVICES PTE LTD  
( MECHANICAL TESTING SECTION )  
531 BUKIT BATOK STREET 23  
SINGAPORE 659547

**Description** : PRESSURE GAUGE

**Manufacturer** : CAPRI

**Serial No.** : GU 47

**Nominal Gauge Size** : 63 ( mm )

**Range** : 0 - 4 ( bar )

**Scale Interval** : 1.0 ( bar )

**Calibration Location** : SETSCO SERVICES PTE LTD , MECHANICAL CALIBRATION LABORATORY .  
The instrument was calibrated under the conditions stated above .

**Ambient Temperature** : 20 ± 2 °C

**Relative Humidity** : 55 ± 10 %

**Date Received** : 21 July 2023

**Receiving Condition** : Satisfactory

**Date of Calibration** : 28 July 2023

**Recommended Due** : 28 July 2024

**Method of Calibration**

The method of calibration is generally stated in SETSCO Procedure MTD / CAL - 05 : 2022 and BS EN 837 - 1 : 1998 as a guide .  
The true method was used to effect the calibration .

**Reference Instrument Traceability** : NMC SINGAPORE , NPL , NVLAP , PTB , NIST , etc .

The following reference instrument used for the calibration are traceable to National or Inter - National standards through recognized metrology institutes .

No.	Description	Serial No.	Calibration Certificate	Calibration Date	Due Date
1 .	DIGITAL PRESSURE GAUGE	211H22110007	CM - 270768 / 30 / 01	04 / 07 / 2023	04 / 01 / 2024

**As Found Results**

**Specification : ± 1.6 % F.S**

Applied Pressure ( bar )	Indicated Pressure ( bar )			
	Increasing		Decreasing	
	Mean Reading	Error	Mean Reading	Error
0.00	-	-	-	-
0.80	0.79	-0.01	0.81	0.01
1.60	1.59	-0.01	1.61	0.01
2.40	2.39	-0.01	2.41	0.01
3.20	3.19	-0.01	3.21	0.01
4.00	3.99	-0.01	-	-

**Accuracy of the pressure instrument was found within ± 1.6% of the maximum scale value .**

Expanded Uncertainty = 0.03 ( bar ) Coverage : k - factor = 2.090

**The measured values were observed to be within tolerance at the calibrated points when the measurement of uncertainty is taken into account .**

The expanded uncertainty of measurement associated with the calibration is at a confidence level of approximately 95% .

**Remarks :**



1. If the pressure instrument is dismantled , or subject to major repairs or adjustment , or if there is any reason to doubt the accuracy of its results, it shall be re - verified .
2. The user should determine the suitability of the instrument for its intended use .
3. No adjustment was made on the instrument .



GANESAN KARTHIKEYAN  
Calibration Officer



RAJ KUMAR  
Principal Engineer ( Calibration & Measurement )  
Mechanical Technology Division

	<b>REVIEWED BY</b>	
		
Name:		Chen Yu
Date :		4/ 8/ 2023

**Terms & Conditions:**

- (1) The Report is prepared for the sole use of the Client and is prepared based upon the Item submitted, the services required by the Client and the conditions under which the Services are performed by SETSCO. The Report is not intended to be representative of similar or equivalent Services on similar or equivalent items. The Report does not constitute an endorsement by SETSCO of the item.
- (2) SETSCO agrees to use reasonable diligence in the performance of the Services but no warranties are given and done may be implied directly or indirectly relating to the Services, the Report or the facilities of SETSCO.
- (3) SETSCO shall under no circumstances be liable to the Client or its agents, servants or representatives, in contract, tort (including negligence or breach of statutory duty) or otherwise for any direct or indirect loss or damage suffered by the Client, its agents, servants or representative howsoever arising or whether connected with the Services provided by SETSCO herein.
- (4) The Report may not be used in any publicity material without the written consent of SETSCO.
- (5) The Report shall not be reproduced in part or in full unless approval in writing has been given by SETSCO.



LA-1993-0051-C LA-1998-0144-D  
LA-1993-0067-G LA-2000-0181-F  
LA-1994-0065-A LA-2012-0519-E  
LA-1987-0001-B



# ATLANTIC SOLUTION PTE LTD

31 Woodlands Close, #05-35, Woodlands Horizon, Singapore 737855  
Tel: +65 6339 0461 | Fax: +65 6339 2796 | Email: info@atlanticsolution.com.sg  
Website: www.atlanticsolution.com.sg

## CALIBRATION CERTIFICATE

CLIENT	: LINGJACK ENGINEERING WORKS PTE LTD	CERTIFICATE NUMBER	: ASN-23-4764
	01 Woodland Terrace,	ISSUE DATE	: 26-Sep-23
	Lingjack Industrial Building	W/O NUMBER	: AWO-23-2250
	Singapore 738471	DATE RECEIVED	: 21-Sep-23

---

INSTRUMENT	: FLOWMETER	CALIBRATION DATE	: 26-Sep-23
MAKER	: TSI	DUE DATE	: 26-Sep-24
MODEL NO	: EMF-300E	STATUS	: As Found
SERIAL NO	: 1922	AMBIENT TEMPERATURE	: 23±5°C
TAG NO	: FLOWPOD 3000 / LJG-018	RELATIVE HUMIDITY	: 55±10%
		PAGE NO	: 1 of 1

### METHOD OF CALIBRATION

The calibration method was carried out according to In-House Technical Calibration Procedure AS-TM-M13 as a guide.

### REFERENCE EQUIPMENTS USED

The calibration was carried out with reference to the following calibration and measurement standards which are traceable to International system of units (SI) and/or to units of measurement realised at the National Metrology Centre (NMC), Singapore or other recognized national metrology institutes

REFERENCE EQUIPMENT	S/NO	ISSUE DATE
MAGNETIC FLOWMETER	EBI-22120011001	14-DEC-22

### CALIBRATION RESULTS

REFERENCE READINGS	INDICATED INSTRUMENTS READINGS	ERROR
	Before adjustment	
l/min	l/min	l/min
199.52	200	0.48
249.44	250	0.56
499.31	500	0.69
699.47	700	0.53
999.57	1000	0.43

### REMARKS

1. The user should determine the suitability of the instrument for its intended use.
2. The recalibration interval should be determined based on customer's requirement.
3. The instrument has been calibrated at the ambient conditions stated above.
4. No adjustment done.

CALIBRATED BY  
JATISENA



APPROVED BY  
S.J. PAUL

This certificate may not be produced other than in full, except with the prior written approval of the issuing Laboratory