

CERTIFICATE OF CONFORMITY

This Certificate is issued to

LINGJACK ENGINEERING WORKS PTE LTD

(UEN No.: 199103053M)

No. 1 Woodlands Terrace, Lingjack Industrial Building, Singapore 738471

For Product Certification Scheme: Type 5

Product : Fire Hose Reel

Brand : COMBAT

Model : HR-1SSW & HR-1SW

Country of Origin : Singapore

Product Details : Swing type fire hose reel with semi-rigid hose.
Hose Nominal Bore: 25mm
Hose Maximum Length: 30m

which has complied with the requirements of the scheme based on the following:

STANDARD(S) TEST REPORT(S)

EN 671-1: 2012	BRE Test Report No.: 252162
	SETSCO Assessment Report No.: MM-8500094418/CY/1
	SETSCO Assessment Report No.: MM-8500094418/CY/2
	SETSCO Test Report No.: MM-8500076870/NKG/4
	SETSCO Test Report No.: MM-8500076870/NCC/2
	SETSCO Test Report No.: MM-8500076870/CCH/1
	SETSCO Test Report No.: MM-8500076870/NKG/3

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd

Certificate No
FSP-2010-0006

Date of Issue
04/12/2024

Date of Expiry
28/12/2029

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10