

CERTIFICATE OF CONFORMITY

This Certificate is issued to

LINGJACK ENGINEERING WORKS PTE LTD

(UEN No.: 199103053M)

No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building, Singapore 738471

For Product Certification Scheme: Type 5

Product : Landing Valve

Brand : COMBAT

Model : DH6i Flange, DH6i Screw

Country of Origin : Singapore

Product Details : High pressure type landing valve

Model	Product Description
DH6i Flange	2 1/2" bib nosed flanged inlet, high pressure
DH6i Screw	2 1/2" bib nosed screwed inlet, high pressure

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

BS 5041 Part 1: 1987

TEST REPORT(S)

BRE Test Report No.: 257784

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No

FSP-2021-1086

Date of Issue

07/02/2022

Date of Expiry

06/02/2027

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.