



CERTIFICATE OF CONFORMITY

No. CLS1A 106093 0021 Rev. 00

Initial No. -

Certificate Holder: LINGJACK ENGINEERING WORKS PTE LTD
1 Woodlands Terrace
#03-01
Lingjack Industrial Building
Singapore 738471
SINGAPORE

UEN - 199103053M

Certification Mark:



Product: Fire Extinguishers
Brand Name: COMBAT
Model(s): C-9FSE
Product Details: 9 Litres Foam (84% Water + 1% SC6 + 15% Inilam A)
Stored Pressure Type Portable Fire Extinguisher
Fire Rating Achieved: 34A / 233B

Standard(s): SS EN 3-7:2012 (2020)
SS EN 3-8:2023

Country of Origin: Singapore

Test Report(s): BRE 252297, 7191377648-MEC26/10-TQH, TÜV SÜD PSB
Supplemental Letter 7191377648

Valid until: 2028-03-22

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 1

Issued on: 2026-05-15

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg