



CERTIFICATE OF CONFORMITY

No. CLS1A 106093 0017 Rev. 01

Initial No. CLS1A 106093 0017 Rev. 00

Certificate Holder:

LINGJACK ENGINEERING WORKS PTE LTD

1 Woodlands Terrace
#03-01
Lingjack Industrial Building
Singapore 738471
SINGAPORE

UEN - 199103053M

Certification Mark:



Product:

Fire Extinguishers

Brand Name:

COMBAT

Model(s):

C-1ASE, C-2ASE, C-3ASE, C-4ASE, C-6ASE, C-9ASE

Product Details:

1kg, 2kg, 3kg, 4kg, 6kg, 9kg Dry Powder
Stored Pressure Type Portable Fire Extinguisher
Refer to following page(s)

Standard(s):

SS EN 3-7:2012 (2020)
SS EN 3-8:2023

Country of Origin:

Singapore

Test Report(s):

Refer to following page(s)

Valid until:

2028-03-22

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

Issued on: 2026-06-17

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg



CERTIFICATE OF CONFORMITY

No. CLS1A 106093 0017 Rev. 01

Initial No. CLS1A 106093 0017 Rev. 00

Product Details:

Fire Ratings and Specifications of "C-1ASE, C-2ASE, C-3ASE, C-4ASE, C-6ASE & C-9ASE" Dry Powder Stored Pressure Type Portable Fire Extinguisher

Brand	Model	Specification	Fire Rating Achieved
COMBAT	C-1ASE	1kg ABC 40 Dry Powder Stored Pressure Type Portable Fire Extinguisher	5A / 55B
	C-2ASE	2kg ABC 40 Dry Powder Stored Pressure Type Portable Fire Extinguisher	13A / 55B
	C-3ASE	3kg ABC 40 Dry Powder Stored Pressure Type Portable Fire Extinguisher	13A / 55B
	C-4ASE	4kg ABC 40 Dry Powder Stored Pressure Type Portable Fire Extinguisher	21A / 144B
	C-6ASE	6kg ABC 40 Dry Powder Stored Pressure Type Portable Fire Extinguisher	34A / 233B
	C-9ASE	9kg ABC 40 Dry Powder Stored Pressure Type Portable Fire Extinguisher	43A / 233B

Test Report(s):

BRE 237709, BRE 252194, BRE 252195, BRE 252196, BRE 252197, SETSCO MM-50071/CCH/4, SETSCO MM-8500071362/CCH, 7191377648-MEC26/01-TQH, 7191377648-MEC26/02-TQH, 7191377648-MEC26/03-TQH, 7191377648-MEC26/05-TQH, 7191377648-MEC26/08-TQH, 7191377648-MEC26/13-TQH & TÜV SÜD PSB Supplemental Letter 7191377648

Replacement History:

Predecessor Certificate (Issue Date)
CLS1A 106093 0017 Rev. 00 (2026-05-15)

Page 2 of 2

Issued on: 2026-06-17

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg