



CERTIFICATE OF CONFORMITY

No. CLSAN 106093 0023 Rev. 00

Initial No. -

Certificate Holder:

LINGJACK ENGINEERING WORKS PTE LTD

1 Woodlands Terrace
#03-01
Lingjack Industrial Building
Singapore 738471
SINGAPORE

UEN - 199103053M

Certification Mark:



Product:

Mobile Fire Extinguishers

Brand Name:

COMBAT

Model(s):

C-25ATP, C-50ATP, C-50ATC, C-75ATC, C-100ATC,
C-150ATC, C-25PTP, C-50PTP, C-50PTC, C-75PTC,
C-100PTC, C-150PTC, C-25MTC, C-50MTC, C-100MTC,
C-25FTP, C-50FTP, C-50FTC, C-100FTC, C-135FTC,
C-20C, C-30C

Product Details:

Refer to following page(s)

Standard(s):

BS EN 1866-1:2007

Country of Origin:

Singapore

Test Report(s):

Refer to following page(s)

Valid until:

2027-07-27

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 3

Issued on: 2026-06-29

Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg



CERTIFICATE OF CONFORMITY

No. CLSAN 106093 0023 Rev. 00

Initial No. -

Product Details:

Fire Ratings and Type / Specifications of Mobile Fire Extinguishers

Brand	Model	Type / Specification	Fire Rating Achieved
COMBAT	C-25ATP	25kg ABC Powder Stored Pressure	34A / II B (275B)
	C-50ATP	50kg ABC Powder Stored Pressure	34A / II B (275B)
	C-50ATC	50kg ABC Powder, 1.5kg CO2 Gas Cartridge Operated	34A / IV B (317B)
	C-75ATC	75kg ABC Powder, 3kg CO2 Gas Cartridge Operated	34A / IV B (317B)
	C-100ATC	100kg ABC Powder, 3.5kg CO2 Gas Cartridge Operated	34A / IV B (317B)
	C-150ATC	150kg ABC Powder, 4kg CO2 Gas Cartridge Operated	34A / IV B (317B)
	C-25PTP	25kg Purple K BC Powder Stored Pressure	II B (275B)
	C-50PTP	50kg Purple K BC Powder Stored Pressure	II B (275B)
	C-50PTC	50kg Purple K BC Powder, 1.5kg CO2 Gas Cartridge Operated	IV B (317B)
	C-75PTC	75kg Purple K BC Powder, 3kg CO2 Gas Cartridge Operated	IV B (317B)
	C-100PTC	100kg Purple K BC Powder, 3.5kg CO2 Gas Cartridge Operated	IV B (317B)
	C-150PTC	150kg Purple K BC Powder, 4kg CO2 Gas Cartridge Operated	IV B (317B)
	C-25MTC	25kg Monnex BC Powder, 1kg CO2 Gas Cartridge Operated	III B (296B)
	C-50MTC	50kg Monnex BC Powder, 1.5kg CO2 Gas Cartridge Operated	III B (296B)
	C-100MTC	100kg Monnex BC Powder, 3.5kg CO2 Gas Cartridge Operated	III B (296B)
	C-25FTP	25 Litres Foam Stored Pressure	34A / II B (275B)
	C-50FTP	50 Litres Foam Stored Pressure	34A / II B (275B)
	C-50FTC	50 Litres Foam, 1kg CO2 Gas Cartridge Operated	34A / IV B (317B)

Page 2 of 3

Issued on: 2026-06-29

Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg



CERTIFICATE OF CONFORMITY

No. CLSAN 106093 0023 Rev. 00

Initial No. -

C-100FTC	100 Litres Foam, 2kg CO2 Gas Cartridge Operated	34A / IV B (317B)
C-135FTC	135 Litres Foam, 3kg CO2 Gas Cartridge Operated	34A / IV B (317B)
C-20C	20kg CO2 Stored Pressure	89B
C-30C	30kg CO2 Stored Pressure	113B

**The product "Mobile Fire Extinguishers" does not fall under SCDF's List of Regulated Fire Safety Products*

Test Report(s):

BRE 277267, BRE 277268, BRE 277270, BRE 277271, BRE 277272, BRE 277273, BRE 277279, BRE 277280, BRE 277281, BRE 277282, BRE 277283, BRE 277284, BRE 277275, BRE 277276, BRE 277278, BRE 277285, BRE 277286, BRE 277287, BRE 277288, BRE 277289, BRE 280614, BRE 280615

Page 3 of 3

Issued on: 2026-06-29

Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg