

CERTIFICATE OF CONFORMITY

This Certificate is issued to

LINGJACK ENGINEERING WORKS PTE LTD
No. 1 Woodlands Terrace
#03-01 Industrial Building
Singapore 738471

For Product Certification Scheme: Type 5

Product : **Mobile Fire Extinguisher**
Brand : **COMBAT**
Model : **Refer to Appendix**
Country of Origin : **Singapore**
Product Details : **Refer to Appendix**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
BS EN 1866-1: 2007	Refer to Appendix

SETSCO



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
BCM-2019-0060	28/07/2018	25/11/2019	27/07/2021

**This product is not under the SCDF list of regulated fire safety products/materials.*

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

Model	Capacity & Type of Mobile Fire Extinguisher	Fire Rating	Test Report No.
C-25ATP	25kg ABC Powder, Stored Pressure	34A, II B (275B)	277267
C-50ATP	50kg ABC Powder, Stored Pressure	34A, II B (275B)	277268
C-50ATC	50kg ABC Powder, 1.5 KG CO ₂ Cartridge Operated	34A, IV B (317B)	277270
C-75ATC	75kg ABC Powder, 3 KG CO ₂ Cartridge Operated	34A, IV B (317B)	277271
C-100ATC	100kg ABC Powder, 3.5 KG CO ₂ Cartridge Operated	34A, IV B (317B)	277272
C-150ATC	150kg ABC Powder, 4 KG CO ₂ Cartridge Operated	34A, IV B (317B)	277273
C-25PTP	25kg BC Purple K Powder, Stored Pressure	II B (275B)	277279
C-50PTP	50kg BC Purple K Powder, Stored Pressure	II B (275B)	277280
C-50PTC	50kg Purple K BC Powder, 1.5 KG CO ₂ Gas Cartridge Operated	IV B (317B)	277281
C-75PTC	75kg Purple K BC Powder, 3 KG CO ₂ Gas Cartridge Operated	IV B (317B)	277282
C-100PTC	100kg Purple K BC Powder, 3.5 KG CO ₂ Gas Cartridge Operated	IV B (317B)	277283
C-150PTC	150kg Purple K BC Powder, 4 KG CO ₂ Gas Cartridge Operated	IV B (317B)	277284
C-25MTC	25kg Monnex BC Powder, 1 KG CO ₂ Gas Cartridge Operated	III B (296B)	277275
C-50MTC	50kg Monnex BC Powder, 1.5kg CO ₂ Gas Cartridge Operated	III B (296B)	277276
C-100MTC	100kg Monnex BC Powder, 3.5 KG CO ₂ Cartridge Operated	III B (296B)	277278
C-25FTP	25 Litre Foam, Stored Pressure	34A, II B (275B)	277285
C-50FTP	50 Litre Foam, Stored Pressure	34A, II B (275B)	277286
C-50FTC	50 Liter Foam, 1 KG CO ₂ Gas Cartridge Operated	34A, IV B (317B)	277287
C-100FTC	100 Litre Foam, 2 KG CO ₂ Gas Cartridge Operated	34A, IV B (317B)	277288
C-135FTC	135 Litre Foam, 3 KG CO ₂ Gas Cartridge Operated	34A, IV B (317B)	277289
C-20C	20kg CO ₂ Stored Pressure	89B	280614
C-30C	30kg CO ₂ Stored Pressure	113B	280615



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
BCM-2019-0060	28/07/2018	25/11/2019	27/07/2021

**This product is not under the SCDF list of regulated fire safety products/materials.*

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.