

CERTIFICATE OF CONFORMITY

This Certificate is issued to
LINGJACK ENGINEERING WORKS PTE LTD
No. 1 Woodlands Terrace
#03-01 Lingjack Industrial Building
Singapore 738471

For Product Certification Scheme: Type 5

Product : Landing Valve
Brand : COMBAT
Model : Refer to Appendix
Country of Origin : Singapore
Product Details : Refer to Appendix

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
BS 5041 Part 1: 1987	BRE Test Report No.: 255924 BRE Test Report No.: 257781 BRE Test Report No.: 257782 BRE Test Report No.: 257783 BRE Test Report No.: 257784



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2010-0009

Date of Original Issue
07/02/2017

Date of Expiry
06/02/2022




This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com



The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

Model	Description
LV-DR25	2½" PN16, oblique, screwed inlet, low pressure
LV-OF25	2½" PN16, oblique, flanged inlet, low pressure
LV-RA25	2½" PN16, right angle, screwed inlet, low pressure
LV-RAF25	2½" PN16, right angle, flanged inlet, low pressure
LV-HS25	2½" PN16, horizontal, screwed inlet, low pressure
LV-HF25	2½" PN16, horizontal, flanged inlet, low pressure
LV-BNS25	2½" PN16, bib nosed, screwed inlet, low pressure
LV-BNF25	2½" PN16, bib nosed, flanged inlet, low pressure
DH6i Screw	2½" bib nosed, screwed inlet, low pressure
DH6i Flange	2½" bib nosed, flanged inlet, low pressure



Sze Thiam Siong (Mr)
 General Manager
 SETSCO Services Pte Ltd
 18 Teban Gardens Crescent
 Singapore 608925

Certificate No
FSP-2010-0009

Date of Original Issue
07/02/2017

Date of Expiry
06/02/2022

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.