

CERTIFICATE OF CONFORMITY

This Certificate is issued to

LINGJACK ENGINEERING WORKS PTE LTD
No. 1 Woodlands Terrace
Singapore 738471

For Product Certification Scheme: Type 5

Product : **Fire Extinguisher**
Brand : **COMBAT**
Model : **Refer to Appendix**
Country of Origin : **Singapore**
Product Details : **Refer to Appendix**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
SS EN 3-7: 2012	Refer to Appendix
BS EN 3-7: 2004 + A1: 2007	
SS EN 3-8: 2012	
BS EN 3-8: 2006	
BS EN 3-9: 2006	



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
FSP-2013-0128	23/04/2018	19/10/2018	22/03/2023



This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com



The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.



Test Report (s)	
BRE Test Report No.: 242435	BRE Test Report No.: 252930
BRE Test Report No.: 242436	BRE Test Report No.: 252929
BRE Test Report No.: 252297	BRE Test Report No.: 259386
BRE Test Report No.: 252196	BRE Test Report No.: 259385
BRE Test Report No.: 252197	BRE Test Report No.: 256373
BRE Test Report No.: 237709	BRE Test Report No.: 276267
BRE Test Report No.: 252194	APRAGAZ Report No. EN 10975
BRE Test Report No.: 252195	MM-50071/CCH/1
BRE Test Report No.: 283686	MM-50071/CCH/2
BRE Test Report No.: 266738	MM-50071/CCH/3
BRE Test Report No.: 276265	MM-50071/CCH/4
BRE Test Report No.: 254220	PSB Corporation Test Report: 25T0000394/6/GCP
MPA Report No.: 20141656/TE02	PSB Corporation Test Report: 54S03031/1/GCP
MPA Report No.: 20141656/TE04	PSB Corporation Test Report: 54S03031/2/GCP
MPA Report No.: 20141656/TE06	PSB Corporation Test Report: 54S03031/3/GCP
MPA Report No.: 20171326/LG02	MPA Report No.: 20141656/TE05
MPA Report No.: 20141670/TE01	MPA Report No.: 20141656/TE07
MPA Report No.: 20141656/TE03	MPA Report No.: 20171326/LG01

Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
FSP-2013-0128	23/04/2018	19/10/2018	22/03/2023

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.



Model	Type	Fire Rating	Capacity	Test Report	Test Standard
C-9WCEA	Water Additive Cartridge	21A	9L	252930	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-9FCE	Foam Cartridge	34A/233B	9L	252929	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-12ACE	ABC Powder gas Cartridge	55A/233B	12kg	259386	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-9ACE	ABC Powder gas Cartridge	43A/233B	9kg	259385	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-6ACE	ABC Powder gas Cartridge	27A/233B	6kg	256373	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-12PKCE	Purple K BC Powder CO ₂ Cartridge	233B	12kg	276267	BS EN 3-7: 2004 + A1: 2007
C-11MCE	Monnex BC Powder CO ₂ Cartridge	233B	11kg	283686	BS EN 3-7: 2004 + A1: 2007
C-2HSE	Clean Agent (HALOTRON), Stored Pressure	5A/34B	2kg	54S03031/1/GCP MM-50071/CCH/3	SS EN 3-7: 2012 SS EN 3-8: 2012
C-4HSE	Clean Agent (HALOTRON), Stored Pressure	8A/55B	4kg	54S03031/2/GCP MM-50071/CCH/2	SS EN 3-7: 2012 SS EN 3-8: 2012
C-6HSE	Clean Agent (HALOTRON), Stored Pressure	13A/70B	6kg	54S03031/3/GCP MM-50071/CCH/1	SS EN 3-7: 2012 SS EN 3-8: 2012
EX-WM1	Water Mist, Stored Pressure	5A	1.4L	20141670/TE01	BS EN 3-7: 2004 + A1: 2007
EX-WM2	Water Mist, Stored Pressure	5A/21B/25F	2L	20141656/TE02	BS EN 3-7: 2004 + A1: 2007
EX-WM3	Water Mist, Stored Pressure	8A/21B/25F	3L	20141656/TE03	BS EN 3-7: 2004 + A1: 2007
EX-WM6	Water Mist, Stored Pressure	13A/21B/40F	6L	20141656/TE04	BS EN 3-7: 2004 + A1: 2007
EX-WM9	Water Mist, Stored Pressure	21A/21B/40F	9L	20141656/TE05	BS EN 3-7: 2004 + A1: 2007
EX-GFM2	Water Mist with Additives, Stored Pressure	5A/55B/25F	2L	20141656/TE06	BS EN 3-7: 2004 + A1: 2007
EX-GFM6	Water Mist with Additives, Stored Pressure	13A/144B/40F	6L	20141656/TE07	BS EN 3-7: 2004 + A1: 2007
C-2AWM	Water Mist with Additives, Stored Pressure	8A/21B/25F	2L	20171326/LG01	BS EN 3-7: 2004 + A1: 2007
C-6AWM	Water Mist with Additives, Stored Pressure	21A/21B/40F	6L	20171326/LG02	BS EN 3-7: 2004 + A1: 2007

Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
FSP-2013-0128	23/04/2018	19/10/2018	22/03/2023

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.



Model	Type	Fire Rating	Capacity	Test Report	Test Standard
C-2CSEC	Carbon Dioxide, Stored Pressure	34B	2kg	242435	BS EN 3-7: 2004 + A1: 2007 BS EN 3-9: 2006
C-5CSEC	Carbon Dioxide, Stored Pressure	55B	5kg	242436	BS EN 3-7: 2004 + A1: 2007 BS EN 3-9: 2006
C-9FSE	Foam, Stored Pressure	34A/233B	9kg	252297	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-1ASE	ABC Powder, Stored Pressure	5A/55B	1kg	252196	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-2ASE	ABC Powder, Stored Pressure	13A/55B	2kg	252197	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-3ASE	ABC Powder, Stored Pressure	13A/55B	3kg	25T0000394/6/GCP MM-50071/CCH/4	SS EN 3-7: 2012 SS EN 3-8: 2012
C-4ASE	ABC Powder, Stored Pressure	21A/144B	4kg	237709	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-6ASE	ABC Powder, Stored Pressure	34A/233B	6kg	252194	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-9ASE	ABC Powder, Stored Pressure	43A/233B	9kg	252195	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-9MSE	Monnex BC Powder, Stored Pressure	233B	9kg	276265	BS EN 3-7: 2004 + A1: 2007
C-9WSEA	Water Additive, Stored Pressure	21A	9L	254220	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006
C-6KSE	Wet Chem	21A/113B/75F	6L	EN 10975	BS EN 3-7: 2004 + A1: 2007
C-9PKSE	Purple K BC Powder, Stored Pressure	233B	9kg	266738	BS EN 3-7: 2004 + A1: 2007 BS EN 3-8: 2006

Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2013-0128

Date of Issue
23/04/2018

Date of Last Revision
19/10/2018

Date of Expiry
22/03/2023

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.